



Sealant, Waterproofing and Restoration Institute
14 West Third Street
Kansas City, MO 64105
Phone: (816) 472-7974
Fax: (816) 472-7765

Product Name: DuraLink Super Adhesion Sealant

Submitted by: CHEM LINK INC
353 E Lyons St.
Schoolcraft, MI 49087
dkelley@chemlink.com
www.chemlinkinc.com

Test Results

ASTM C 719 Adhesion and Cohesion of Elastomeric Joint Sealants Under Cyclic Movement [Hockman Cycle]; Pass: Yes
Extension: +50% Compression: -50% Substrate: Mortar, Aluminum, Glass [Mortar substrates were primed with Chem Link Primer 52.]

ASTM C 661 Test Method for Indentation Hardness of Elastomeric - Type Sealants by Means of Durometer Hardness;
Shore "A" Durometer Rating: 30

Validation Date: 6/28/2007

Expiration Date: 6/27/2012

Lab Details: DL Laboratories
74 Kent St.
Brooklyn, NY 11222-1517
Phone: 718-383-5080
Fax: 718-383-7445
